

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-1483:133 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Mirtone, 90 Fieldstone Ct., Cheshire, CT 06410  
Contact: Brad Miller (888) 649-9827

**DESIGN:** Models INT-3A-T, INT-3A-TW, INT-5A-T, INT-5A-TW, INT-7A-T, INT-7A-TW, INT-8A-T, INT-8A-TW, INT-15PS\*, -15PSW\*, -75PS\* and -75PSW\* horn/strobes. These devices are combinations of and audible signal appliance and a visual signaling appliance GS's Model 202-3A, -5A, -7A or -8A (See CSFM Listing 7125-1388:190 for details). Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Horn: 20-24 VDC  
Strobe: -3A: 30 cd, -5A, -15PS\*, -15PSW\*: 15 cd, -75PS\*, -75PSW\*: 75cd  
-7A:15/75 cd, -8A: 110 cd,

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical/candela ratings and UL label.

**APPROVAL:** Listed as audible/visual devices for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired applications and for indoor use only.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**XLF:** 7125-1388:214

\*Rev. 11-02-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE AREND, Senior Deputy  
Program Manager**